

# CERTIFICATE OF CONFORMITY

**Certificate No.:** LC22395-1

**Date Issued:** January 24, 2025


**Project No.:** 22395

**Certification System: Type 3**  
(ISO / IEC 17067)

**Client No.:** LC1231751

**Applicant:** Victron Energy B.V.  
De Paal 35  
1351 JG Almere  
Netherlands



**Issued by:**   
Certification Manager

## Products:

- Inverter/Charger
- Model: MultiPlus-II 48/5000/70-95 120V
- Ratings: AC input: 90 – 140 VAC, 95 A, 55 – 65 Hz  
AC output: 120 VAC, 33 A, 60 Hz  
DC input: 38 – 66 VDC, 110 A  
DC output: 48 VDC, 70 A

## Applicable requirements:

- UL 1741 2<sup>nd</sup> Edition
- CSA C22.2 No. 107.1-16

## Conditions of acceptability:

- None

## General Note:

- Refer to LC Listing Report no. 10.00.22395-1\_Rev.0